

TEST REPORT

REPORT NO. :	2015MA0530	PAGE:	1 OF 5
This Test Report refers only to samples submitted by the applicant to SIRIM QAS International Sdn. Bhd. and tested by SIRIM QAS International Sdn. Bhd. This Test Report shall not be reproduced, except in full and shall not be used for any purpose by any means or forms (including but not limited to advertising purposes) without written approval from Managing Director, SIRIM QAS International Sdn. Bhd. Please refer overleaf of Page 1 for Conditions Relating to the Use of Test Report.			

Applicant : NEWFLO CORPORATION SDN. BHD.
No. 4 & 6, Jalan Balakong Jaya 4,
Taman Industri Balakong Jaya,
Selangor Darul Ehsan.

Manufacturer : Not Stated.

Product : Brass Gate Valves & Brass Ball Valves.

Reference Standard/ : BS EN 12266-1: 2012 – Industrial Valves – Testing of Metallic Valves -
Part 1. Pressure Tests. Test Procedures & Acceptance Criteria – Mandatory
Requirements.

Method of test : Pressure Test.

Description of sample/ Description of Test Specimen : Brand : MIHA.
Model : Refer To Page 3 & Page 5.
Quantity: One (1) Unit.

Date Received of Complete Application : 07 August 2015.

Job No. : J20151390504.

Description of Test Results/ Overall Test Result : The test results for the submitted test samples as described in this test report complied with the requirements of the above reference standard.

Issued date : 08 SEP 2015

Approved Signatory


(MOHD AZLAN BIN MUSTAFFA)
Senior Technical Executive



(MOHD FAIZAR BIN MUSTAFA)
Head
Mechanical & Automotive Section (MAST)
Testing Services Department

This Test Report refers only to samples submitted by the applicant to SIRIM QAS International Sdn. Bhd. and tested by SIRIM QAS International Sdn. Bhd. This Test Report shall not be reproduced, except in full and shall not be used for any purpose by any means or forms (including but not limited to advertising purposes) without written approval from Managing Director, SIRIM QAS International Sdn. Bhd. Please refer overleaf for Conditions Relating to the Use of Test Report contain in this Test Report shall apply.

Photograph of test samples
(Brass Ball Valves)



[Handwritten signature]

REPORT NO. :	2015MA0530	PAGE:	5	OF	5
This Test Report refers only to samples submitted by the applicant to SIRIM QAS International Sdn. Bhd. and tested by SIRIM QAS International Sdn. Bhd. This Test Report shall not be reproduced, except in full and shall not be used for any purpose by any means or forms (including but not limited to advertising purposes) without written approval from Managing Director, SIRIM QAS International Sdn. Bhd. Please refer overleaf for Conditions Relating to the Use of Test Report contain in this Test Report shall apply.					

Product: Brass Ball Valves.

Nominal Diameter: DN15 ~ DN50.

Nominal Pressure: PN16.

DN	Pressure (bar)		Duration (minute)		Results
	Body	Seat (both side)	Body	Seat (both side)	
15	24	17.6	10	10	No leakage observed.
20	24	17.6	10	10	No leakage observed.
25	24	17.6	10	10	No leakage observed.
32	24	17.6	10	10	No leakage observed.
40	24	17.6	10	10	No leakage observed.
50	24	17.6	10	10	No leakage observed.



[Handwritten signature]