

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20150709-EX26457  
**Report Reference** EX26457-20150408  
**Issue Date** 2015-JULY-09

**Issued to:** SHANDONG LEDE MACHINERY CO LTD  
No 3998  
West Waihuan N Rd  
Weicheng District  
Weifang  
Shandong 261057 CHINA

**This is to certify that representative samples of** BUTTERFLY VALVES  
See addendum page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 1091 - Standard for Butterfly Valves for Fire-Protection Service  
ULC/ORD C1091 - Preliminary Standard for Butterfly valves for fire-protection service  
UL 38 - Standard for Manual Signaling Boxes for Fire Alarm Systems  
UL 753 - Standard for Alarm Accessories for Automatic Water-Supply Control Valves for Fire Protection Service

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20150709-EX26457  
**Report Reference** EX26457-20150408  
**Issue Date** 2015-JULY-09

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

**PRODUCT SUBMITTED:**

UL

Model	Size, in.	Body Type	Pressure Rating, psig	Indicator Post	Supervisory Switch*
XD381X	2,2.5,3,4,5, 5(139.7mm)6,6(165.1mm)	Groove	362	-	I, O
	8		232		I, O
XD371X	2,2.5,3,4,5,6	Wafer	362		I, O
	8,10,12		232		I, O

CUL

*Model	Size, in.	Body Type	Pressure Rating, psig,	Indicator Post	Supervisory Switch*
XD381X	2.5,3,4,5,5(139.7mm),6,6(165.1mm)	Groove	300	-	I, O
	8		232		I, O
XD371X	2.5,3,4,5,6	Wafer	300		I, O
	8,10,12		232		I, O

**Note:**

For the valve sizes 6 in. and smaller, configured with operator CDT-24, for the valve sizes 8 in. and larger, configured with operator CDT-30.

The shaft material designation is SS431



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

